



DECLARATION



Number	20B0359/02	Replaces	--
Date of issue	19-06-2020	Issued first	19-06-2020
Valid till	19-06-2023	Report number	0288-L-19/5

Declaration
regarding the resistance to root penetration of a root protection layer.

DECLARATION OF KIWA BDA EXPERT CENTRE

This declaration is based on a single examination by Kiwa BDA Testing B.V. on one product supplied by

Knauf Insulation d.o.o.

This declaration does not pass a judgment on other products supplied by the manufacturer.
The product was tested according to CEN/TS 14416:2014.

PRODUCT NAME

Urbanscape Root Membrane FLW-500

TEST RESULTS

After the growing period of eight weeks no penetration into or through the test specimens have been observed.

Ron Scheepers
Kiwa

Publication of this certificate is allowed.

Advice: consult www.kiwa.nl in order to ensure that this declaration is still valid.

Kiwa BDA Expert Centre

Department of:
BDA Dak- en Geveladvies B.V.
Avelingen West 33
4202 MS Gorinchem
P.O. Box 389
NL – 4200 AJ Gorinchem
Tel +31(0)183 669690
groep@bda.nl
www.kiwabda.nl
Copyright© 2020 Kiwa BDA

Knauf Insulation d.o.o.

Trata 32
SL-4220 ŠKOFJA LOKA
Tel +386 (0)4 5114 000
oem@knaufinsulation.com
www.oem.knaufinsulation.com

